



Industrial Pump Maintenance Checklist

Pre-Maintenance Safety Procedures

Lockout/Tagout (LOTO) procedures followed

- All power sources shut off (electric, hydraulic, pneumatic)
- Each source locked with assigned lock
- Tags applied with name, date, reason
- Equipment tested for zero energy
- Keys retained by authorized personnel

Hazard Assessment completed

- Slippery surfaces cleaned and marked
- Chemical exposure identified and PPE selected
- Mechanical risks (e.g., exposed belts) guarded
- All hazards communicated to the team

Personal Protective Equipment (PPE) in use

- Safety glasses or goggles
- Chemical-resistant gloves
- Steel-toe boots
- Hard hat
- Hearing protection
- PPE inspected and undamaged

Visual Inspection

External Condition Assessment

- Casing undamaged (no dents/cracks)
- Paint/coating intact
- Labels and warnings readable
- Surfaces clean (no buildup)

Leak Detection

- No fluid around or under pump
- All seals and gaskets dry
- Connections tight
- Leaks marked and reported

Mounting and Alignment

- All bolts secure
- Base and supports undamaged
- Coupling aligned (check with straightedge/laser)
- No movement during operation

Mechanical Component Maintenance

Couplings and Bearings

- Couplings not cracked or worn
- Coupling alignment correct
- Bearings spin smoothly and quietly
- No overheating in bearings
- Mounting bolts tight

Seals and Gaskets

- No drips or moisture at seals
- No cracks, hardening, or swelling in gaskets
- Gland packing and mechanical seals checked
- Correct seal replacements used

Lubrication

Correct oil/grease type used

Lubrication intervals followed:

Small centrifugal: grease every 3 months

Large industrial: oil monthly

Magnetic drive: slide bearing every 6 months

Fittings cleaned before filling

Proper amount added

Old lubricant removed if needed

Lubrication activity logged

Operational Testing Procedures

Startup Test

Power supply verified

Pump and suction line primed

Inlet/outlet valves opened slowly

Pressure within safe range

Listen/observe for abnormal sounds, movement, leaks

Shutdown Test

Cooldown time allowed

Power turned off in correct sequence

Valves closed per manufacturer

Flow Rate Measurement

Flow meter attached

Pump run at normal load

Flow rate recorded and compared to rated capacity

Issues flagged if deviation >10%

Noise & Vibration Analysis

No grinding/squealing from bearings

No shaking/rattling from housing

Piping connections tight

No leaks/hissing from seal area

Abnormal vibration documented and investigated

Documentation & Recordkeeping

Maintenance Log Updated

Pump nameplate info recorded

Date of maintenance

Task performed

Technician name

Tools/checklists used

Irregularities Reported

Date/time of issue

Pump model/serial number

Description of problem (noise, leak, vibration)

Action taken and by whom

Supervisor notified if needed